

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

September 15, 2009

\

AK INDUSTRIES, INC. KURT SNEARLY PO BOX 640 PLYMOUTH IN 46563

Re: Description: SEWAGE TANKS, POLYETHYLENE

Manufacturer: AK INDUSTRIES, INC.
Product Name: HOLDING OR PUMP TANK
Model Number(s): AKS 22200 [1000 GALLON]

(50 IN. L.L., 24 IN. MAX. DEPTH OF BURY, **NOT APPROVED FOR SEPTIC; TANK DIMENSIONS = 102 IN. L X 63 IN. H X 67 IN. W;** GALLON CAPACITY AT SPECIFIED LEVELS - 6 IN./59, 8 IN./92, 10 IN./127, 12 IN./160, 14 IN./200, 16 IN./239, 18 IN./282, 20 IN./325, 22 IN./371, 24 IN./418, 26 IN./463, 28 IN./513, 30 IN./558, 32 IN./619, 34 IN./669, 36 IN./714, 38 IN./763, 40 IN./809, 42 IN./849, 44 IN./892, 46 IN./932, 48 IN./968, 50

IN./1002)

Product File No: 20090327

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of DECEMBER 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
 department's stamp of approval. The plans and specifications must be open to inspection by an authorized
 representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product may not be installed more than 36 inches below final grade.
- A minimum 2" diameter vent must be provided on the building sewer within 12" of the connection to the tank or
 on the tank installed in accordance with the manufacturer instructions.
- BEDDING: Compacted aggregate confirming to tank base at depth and diameter as per manufacturer's installation instructions; dewater excavation prior to installation.

This approval supersedes the approval issued on 12/13/2004 under product file number 20040224.

SBD-10564-E (N.10/97) File Ref: 09032701.DOC

AK INDUSTRIES, INC. Page 2 September 15, 2009 PRODUCT FILE NO. 20090327

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040224.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phanes: 600,000,0055, Faux 600,000,7450

Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov